



BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908

## NOTICE OF ACCEPTANCE (NOA)

PGT Industries  
P.O. Box 1529  
Nokomis, FL 34274

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Series "SGD-70" Aluminum Sliding Glass Door

**APPROVAL DOCUMENT:** Drawing No. 4340, titled "Impact - Alum. Sliding Glass Door", sheets 1 through 6 of 6, prepared by manufacturer, dated 2/16/98 with revision on 6/2/03, signed and sealed by Robert Clark, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

### MISSILE IMPACT RATING: Large and Small Missile Impact

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 02-0306.01 and, consists of this page 1 as well as approval document mentioned above. The submitted documentation was reviewed by **Theodore Berman, P.E.**

10/16/2003



NOA No 03-0512.04  
Expiration Date: May 06, 2007  
Approval Date: November 06, 2003  
Page 1

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Manufacturer's die drawings and sections.
2. Drawing No. **4340**, titled "Impact – Alum. Sliding Glass Door", sheets 1 through 6 of 6, prepared by manufacturer, dated 2/16/98 with revision on 6/2/03, signed and sealed by Robert Clark, P.E.

**B. TESTS**

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94  
2) Large Missile Impact Test per FBC, TAS 201-94  
3) Cyclic Wind Pressure Loading per FBC, TAS 203-94  
along with marked-up drawings and installation diagram of an aluminum sliding glass door, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-03038** dated 5/18/03.

***Submitted under NOA# 02-0306.01***

2. Test reports on 1) Air Infiltration Test, per FBC, TAS 202-94  
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94  
3) Water Resistance Test, per FBC, TAS 202-94  
4) Large Missile Impact Test per FBC, TAS 201-94  
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94  
6) Forced Entry Test, per FBC 2411 3.2.1 and TAS 202-94  
along with marked-up drawings and installation diagram of an aluminum sliding glass door, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-98029** dated 3/17/98.
2. Test reports on 1) Air Infiltration Test, per FBC, TAS 202-94  
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94  
3) Forced Entry Test, per FBC 2411 3.2.1 and TAS 202-94  
along with marked-up drawings and installation diagram of an aluminum sliding glass door, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-02081** dated 7/18/02.

**C. CALCULATIONS**

1. Anchor Calculations, ASTM-E1300-98 and structural analysis, dated 5/7/03, prepared, signed and sealed by Robert Clark, P.E.

**D. MATERIAL CERTIFICATIONS**

1. Notice of Acceptance No. **00-1212.04** issued to E.I. DuPont DeNemours for "Dupont Butacite ® PVB" dated 2/15/01, expiring on 12/11/05.



**Theodore Berman, P.E.**

**Deputy Director, Product Control Division**

**NOA No 03-0512.04**

**Expiration Date: May 06, 2007**

**Approval Date: November 06, 2003**

**PGT Industries**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**E. QUALITY ASSURANCE**


1. Miami-Dade County Building Code Compliance Office.

**F. STATEMENTS**

1. Laboratory compliance letter for Test Report No. **FTL -03038** prepared by Fenestration Testing Laboratory, Inc, dated 4/3/03, signed and sealed by Joseph Chan, P.E.


**G. OTHER**

1. Notice of Acceptance No. **02-0306.01**, issued to PGT Industries, Series "HS 70" Aluminum Sliding Glass Door, approved on 6/27/02 and expiring on 5/6/07.
2. Letter from the consultant stating that the product is in compliance with the Florida Building Code (FBC).




Theodore Berman, P.E.  
Deputy Director, Product Control Division  
NOA No 03-0512.04  
Expiration Date: May 06, 2007  
Approval Date: November 06, 2003

LARGE MISSILE IMPACT SLIDING GLASS DOOR

- 1.) GLAZING OPTIONS:
- A. 7/16" (.454) LAMINATED W/ AN .090 PVB INNER LAYER OF MONSANTO SAFELEX OR DUPONT BUTACITE BETWEEN (2) LITES OF 3/16" HEAT STRENGTHENED GLASS.
  - B. 1 1/16" I.G. CONSISTING OF (1) LITE OF 3/16" TEMPERED GLASS, A 1/2" AIR SPACE AND A 7/16" LAMINATED GLASS. THE 7/16" LAMINATED GLASS COMPONENT CONSIST OF AN .090 PVB INNER LAYER OF MONSANTO SAFELEX OR DUPONT BUTACITE BETWEEN (1) LITE OF 3/16" ANNEALED GLASS AND (1) LITE OF 3/16" HEAT STRENGTHENED GLASS. 
  - C. 1 1/16" I.G. CONSISTING OF (1) LITE OF 3/16" TEMPERED GLASS, A 1/2" AIR SPACE AND A 7/16" LAMINATED GLASS. THE 7/16" LAMINATED GLASS COMPONENT CONSIST OF AN .090 PVB INNER LAYER OF MONSANTO SAFELEX OR DUPONT BUTACITE BETWEEN (2) LITES OF 3/16" HEAT STRENGTHENED GLASS.
- 2.) CONFIGURATIONS: XO/OX/XX
- 3.) DESIGN PRESSURE RATINGS: SEE TABLES  
(NOTE ALLOWABLE PRESSURE DIFFERENCES WITH GLASS UPGRADE OPTION)  
NEG. DESIGN LOADS BASED ON TESTED PRESSURE AND GLASS TABLE ASTM E 1300-98.  
POS. DESIGN LOADS BASED ON WATER TEST PRESSURE AND GLASS TABLE ASTM E 1300-98.
- 4.) ANCHORAGE:  
DOUBLE ROW OF FASTENERS LOCATED AS FOLLOWS AND PER SHEET 4 OF 6.  
HEAD & SILL:  
MAX. 6 1/2" FROM CORNERS.  
AT THE MEETING RAIL CENTERLINE.  
MAX. 4" ON EACH SIDE OF MEETING RAIL CENTERLINE.  
MAX. 21" SPACING.  
JAMBS:  
MAX. 6" FROM CORNERS.  
MAX. 21" SPACING.
- 5.) SHUTTER REQUIREMENT: NO SHUTTERS REQUIRED
- 6.) REFERENCE TEST REPORTS: FTL-1972 & FTL-3741
- 7.) ALL FRAME CORNERS & PANELS SEALED WITH SCHNEE/MOREHEAD SEALANT.

COMPARATIVE ANALYSIS:

FTL-3741




GLASS TYPE B. 1 1/16" I.G., 3/16" TEMPERED, 1/2" AIR SPACE, 7/16" LAMINATED (3/16" A, .090 PVB, 3/16" HS)

TABLE 3. WITH 3.50" HIGH SILL

DOOR WIDTH	DOOR HEIGHT					
	84.000		90.000		96.000	
	NEG	POS	NEG	POS	NEG	POS
84.000	-53.9	53.9	-50.7	50.7	-48.2	48.2
90.000	-49.8	49.8	-44.9	44.9	-43.7	43.7
96.000	-49.1	49.1	-44.0	44.0	-40.7	40.7

TABLE 4. WITH 2.43" HIGH SILL

DOOR WIDTH	DOOR HEIGHT					
	84.000		90.000		96.000	
	NEG	POS	NEG	POS	NEG	POS
84.000	-53.9	46.7	-50.7	46.7	-48.2	46.7
90.000	-49.8	46.7	-44.9	44.9	-43.7	43.7
96.000	-49.1	46.7	-44.0	44.0	-40.7	40.7



(OUTSIDE ELEVATION LOOKING IN)

COMPARATIVE ANALYSIS:

GLASS TYPE A. 7/16" LAMINATED (3/16" HS, .090 PVB, 3/16" HS)

GLASS TYPE C. 1 1/16" I.G., 3/16" TEMPERED, 1/2" AIR SPACE, 7/16" LAMINATED (3/16" HS, .090 PVB, 3/16" HS)

FTL-1972


FTL-3741

TABLE 1. WITH 3.50" HIGH SILL

DOOR WIDTH	DOOR HEIGHT					
	84.000		90.000		96.000	
	NEG	POS	NEG	POS	NEG	POS
84.000	-90.0	90.0	-90.0	90.0	-90.0	90.0
90.000	-90.0	90.0	-89.3	89.3	-87.3	87.3
96.000	-88.8	88.8	-84.6	84.6	-81.2	81.2

TABLE 2. WITH 2.43" HIGH SILL


DOOR WIDTH	DOOR HEIGHT					
	84.000		90.000		96.000	
	NEG	POS	NEG	POS	NEG	POS
84.000	-90.0	46.7	-90.0	46.7	-90.0	46.7
90.000	-90.0	46.7	-89.3	46.7	-87.3	46.7
96.000	-88.8	46.7	-84.6	46.7	-81.2	46.7



  
6/19/03  
Robert L. Clark, P.E.  
PE #39712  
Structural

**PGT**  
**INDUSTRIES**  
  
1070 TECHNOLOGY DRIVE  
NOKOMIS, FL 34275  
  
P.O. BOX 1529  
NOKOMIS, FL 34274

Revsd By: F.K.	Date: 6/2/03	Revisions: ADD GLASS TYPE & TABLE
Revsd By: F.K.	Date: 5/6/03	Revisions: ALT. LOCK & 1 1/16" I.G.
Revsd By: L.T.	Date: 5/15/02	Revisions:
Revsd By: F.K.	Date: 5/22/02	Revisions: E-NO CHG THIS SHT
Drawn By: D.B.	Date: 2/16/98	

Description: ELEVATION				
Title: IMPACT - ALUM. SLIDING GLASS DOOR				
Series/Model: SGD-70	Scale: NTS	Sheet: 1 of 6	Drawing No. 4340	Rev: G

**PRODUCT REVISED**  
as complying with the Florida  
Building Code  
Acceptance No 03-0512.04  
Expiration Date 05/06/07  
  
Robert L. Clark, P.E.  
Product Control  
Division



*Robert L. Clark*  
6/19/02

Robert L. Clark, P.E.  
PE #39712  
Structural

**PGT**  
INDUSTRIES

1070 TECHNOLOGY DRIVE  
NOKOMIS, FL 34275

P.O. BOX 1529  
NOKOMIS, FL 34274



Revsd By: F.K.	Date: 6/2/03	Revisions: G-ADD ITEM 37
Revsd By: F.K.	Date: 5/6/03	Revisions: F-ADD 1 1/16" I.G.
Revsd By: L.T.	Date: 5/15/02	Revisions:
Revsd By: F.K.	Date: 5/22/02	Revisions: E-NO CHG THIS SHT
Drawn By: D.R.	Date: 2/16/98	

Description:  
GLAZING DETAILS

Title:  
IMPACT - ALUM. SLIDING GLASS DOOR

Series/Model: SGD-70	Scale: NTS	Sheet: 2 of 6	Drawing No. 4340	Rev: G
-------------------------	---------------	------------------	---------------------	-----------

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 03-0512.04  
Expiration Date 05/06/07  
By: *Cherish Boone*  
Miami Dade Product Control  
Division



FIXED PANEL JAMB STILE FASTENED TO RIGHT FRAME JAMB W/ ONE ALUMINUM ANCHOR CLIP 7" AND 31-1/2" FROM EACH END (TOTAL OF FOUR), EACH FASTENED W/ TWO NO. 8 BY 1" PAN HEAD SHEET METAL SCREW.

REFERENCE TEST REPORTS: FTL-1972 & FTL-3741

*Robert L. Clark*  
6/14/03  
Robert L. Clark, P.E.  
PE #39712  
Structural

**PGT**  
INDUSTRIES

1070 TECHNOLOGY DRIVE  
NOKOMIS, FL 34275  
P.O. BOX 1529  
NOKOMIS, FL 34274


Revsd By: F.K.	Date: 6/2/03	Revisions: G-ADD ITEM 37
Revsd By: F.K.	Date: 5/6/03	Revisions: F-ALT. LOCK & 1 1/16" I.G.
Revsd By: L.T.	Date: 5/15/02	Revisions:
Revsd By: F.K.	Date: 5/22/02	Revisions: E-NO CHG THIS SHT
Drawn By: D.R.	Date: 2/16/98	

Description:  
SECT. VIEWS - OX (W/O REINF.)

Title:  
IMPACT - ALUM. SLIDING GLASS DOOR


Series/Model: SGD-70	Scale: NTS	Sheet: 3 of 6	Drawing No. 4340	Rev: G
----------------------	------------	---------------	------------------	--------

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 03-0512.04  
Expiration Date 05/06/07  
By *Alvin Brown*  
Miami Dade Product Control  
Division




TYP. HEAD

TYP. HEAD



TYP. SILL



TYP. JAMBS

**NOTE:**

1. USE MIAMI-DADE COUNTY APPROVED ELCO OR ITW TAPCONS.

ITEM	DESCRIPTION	V.T. #	QTY./LOCATION	VENDOR	VENDOR #
1	FRAME HEAD, 2-TRACK	612245	1	ALUMAX	AF-12245
2	FRAME SILL, 2-TRACK	612246	1	ALUMAX	AF-12246
3	THRESHOLD COVER, 2-TRACK	612255	1	ALUMAX	AF-12255
4	FIXED ADAPTER, FRAME SILL	612254	1	ALUMAX	AF-12254
5	FRAME JAMB, 2-TRACK	612247	2	ALUMAX	AF-12247
6	#8 x .750 PH. PN. SMS	7834A	12 (Frame assy. screws)	MERCHANTS FAST.	
7	RAIL, TOP - (PANEL)	612248	2	ALUMAX	AF-12248
8	WSTP, .170 BACK x.270, FIN SEAL	67S16G	24 (moving/fixed panels,screen)	SCHLEGEL CORP.	FS7516-187
9	FIXED PANEL, SIDE RAIL	612249	2	ALUMAX	AF-12249
10	FIXED PANEL, MEETING RAIL	612251	1	ALUMAX	AF-12251
11	#14 x 1.500" PH. PN. SMS	714X112	20 (Panel/Screen assy. screws)	MERCHANTS FAST.	
12	ROLLER, STEEL	71049	2 (1@ea. end X panel bot. rail)	TRUTH HARDWARE	39-10
13	ROLLER, STAINLESS STEEL	71050X	2	TRUTH HARDWARE	39-13
14	PLUG, ROLLER ADJUSTMENT		2		187PW-0988-OAOA
15	OPER. PANEL, SIDE RAIL	612261	1	ALUMAX	AF-12261
16	1.5x1x.5 OPEN-CELL FOAM PAD		5 (1@ea. intermediate weepholes)		
17	FRAME, TOP RAIL SCREEN	612256	1	ALUMAX	AF-12256
18	FRAME, BOT. RAIL SCREEN	612257	1	ALUMAX	AF-12257
19	FRAME, SIDE RAIL SCREEN	612258	1	ALUMAX	AF-12258
20	RAIL, SCREEN MEETING	612259	1	ALUMAX	AF-12259
21	GLAZING BEAD	6534601	8	ALUMAX	AF-534601
22	BULB VINYL, THIN WALL GLZ. BD.	6TP247K	8 (1 per Glazing Bead)	TEAM PLASTICS	TP-247
23	7/16"(.454) W/MONSANTO INTERLAYER		2	H.P.G.	
24	7/16"(.454) W/DUPONT INTERLAYER		2	H.P.G.	
25	SEAM SEALER	6SM55W		SCHNEE/MOREHEAD	SM5504
26	LATCH KEEPER	1046	1 (l.h. fr. jamb, 38" from bot.)	NATIONWIDE	2153
27	HANDLE SET	1045	1 (l.h. lockstile, 40" from bot.)	NATIONWIDE	684
28	SILICONE	62899C		DOW CORNING	899 OR 995
29	FIXED PANEL CLIP	612262	4 (attaches fixed panel to jamb)	ALUMAX	AF-12262
30	#8 x 1.000 Ph. Pn. SMS	78X1PPA	4 (Fixed Panel Clip Screws)	SCHERER	
35	GLAZING BEAD, 1 1/16" LAMI I.G.	4395	8 (4 PER PANEL)	INDALEX	64395
36	1 1/16" LAMI I.G. GLASS	3/16" T, 1/2" SPACE, 7/16" LAMI (3/16" HS, .090 PVB, 3/16" HS)			
37	1 1/16" LAMI I.G. GLASS	3/16" T, 1/2" SPACE, 7/16" LAMI (3/16" A, .090 PVB, 3/16" HS)			



Revsd By: F.K.	Date: 6/2/03	Revisions: G-ADD ITEM 37
Revsd By: F.K.	Date: 5/6/03	Revisions: F-ADD ITEMS 35, 36
Revsd By: L.T.	Date: 5/15/02	Revisions: TAPCON DESIG.
Revsd By: F.K.	Date: 5/22/02	Revisions: CORRECT EMBEDMENTS
Drawn By: D.B.	Date: 2/16/98	

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 03-0512.04  
Expiration Date 05/06/07  
By *[Signature]*  
Miami Dade Product Control  
Division

*[Signature]*  
6/19/03


**PGT**  
**INDUSTRIES**

1070 TECHNOLOGY DRIVE  
NOKOMIS, FL 34275


P.O. BOX 1529  
NOKOMIS, FL 34274

Robert L. Clark, P.E.  
PE #39712  
Structural


Description: ANCHORAGE DETAIL & PARTS LIST				
Title: IMPACT - ALUM. SLIDING GLASS DOOR				
Series/Model: SGD-70	Scale: NTS	Sheet: 4 of 6	Drawing No. 4340	Rev: G




① DWG.#4302  
2-TRACK HEAD  
6063-T5




② DWG.#4303  
2-TRACK SILL  
6063-T5




③ DWG.#4315  
2-TRACK THRESHOLD  
6063-T5




④ DWG.#4314  
FIXED PANEL ADAPTER  
6063-T5




⑤ DWG.#4304  
2-TRACK JAMB  
6063-T5




⑦ DWG.#4305  
TOP & BOT. RAIL  
6063-T5




⑨ DWG.#4306  
SIDE RAIL  
6063-T5




⑩ DWG.#4308  
MEET. RAIL (FIXED)  
6063-HST54




⑮ DWG.#4326  
MOVING PANEL  
MEETING RAIL  
6063-HST54




⑰ DWG.#4317  
SCREEN TOP RAIL  
6063-T5




⑱ DWG.#4318  
SCREEN BOT. RAIL  
6063-T5




⑲ DWG.#4319  
SCREEN SIDE RAIL  
6063-T5



⑳ DWG.#4395  
1 1/16" I.G. GLAZING BEAD  
6063-T5



㉔ DWG.#4320  
SCREEN MEET. RAIL  
6063-T5



㉑ DWG.#4328  
FIXED PANEL CLIP  
6063-T5

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 03-0512.04  
Expiration Date 03/06/07  
By *[Signature]*  
Miami Dade Product Control  
Division

Revsd By: F.K.	Date: 6/2/03	Revisions: G-NO CHG THIS SHT
Revsd By: F.K.	Date: 5/6/03	Revisions: F-ADD ITEM 35
Revsd By: L.T.	Date: 5/15/02	Revisions:
Revsd By: F.K.	Date: 5/22/02	Revisions: E-NO CHG THIS SHT
Drawn By: D.B.	Date: 2/16/98	

Description:  
EXTRUSION PROFILES

Title:  
IMPACT - ALUM. SLIDING GLASS DOOR

Series/Model: SGD-70	Scale: NTS	Sheet: 5 of 6	Drawing No. 4340	Rev: G
-------------------------	---------------	------------------	---------------------	-----------

*[Signature]*  
6/19/03

Robert L. Clark, P.E.  
PE #39712  
Structural


**PCT**  
INDUSTRIES

1070 TECHNOLOGY DRIVE  
NOKOMIS, FL 34275


P.O. BOX 1529  
NOKOMIS, FL 34274



ITEM	DESCRIPTION	V.T. #	QTY./LOCATION	VENDOR	VENDOR #
40	MORTISE LOCK, SURF. MOUNTING	73009NFPX	1 (3 PLY HOOK & INT. THUMB KEY OPERATOR)	TRUTH	
41	MORTISE LOCK KEEPER	22507MLK	1	TRUTH	
42	MORTISE LOCK RECESS ADAPTER	72260MLRA	1	TRUTH	
43	INTERIOR PULL HANDLE		1	TRUTH	
44	EXTERIOR PULL HANDLE (OPT. LOCK)		1	TRUTH	
45	#8 x 1 1/4 PH PN SMS	78X1250PPA	2 (ATTACHES KEEPER)	SCHERER	
46	#10-32 x 1 PH FH TYPE F SS	71032x1FPFX	2 (ATTACHES MORTISE LOCK)	SCHERER	





MORTISE LOCK COMPONENTS



EXTERIOR

TYPICAL 'XO' OR 'OX' CONFIGURATION

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 03-0512.04  
Expiration Date 05/06/07  
By *[Signature]*  
Miami Dade Product Control  
Division

 Robert L. Clark, P.E. PE #39712 Structural	  1070 TECHNOLOGY DRIVE NOKOMIS, FL 34275  P.O. BOX 1529 NOKOMIS, FL 34274	Revsd By: F.K. Date: 6/2/03	Revisions: G-NO CHG THIS SHT	Description: ALTERNATE MORTISE LOCK & HANDLES  Title: IMPACT – ALUM. SLIDING GLASS DOOR	
		Revsd By: F.K. Date: 5/6/03	Revisions: F-ADD ALT. LOCK ASSY		
		Drawn By: D.B. Date: 2/16/98			
		Series/Model: SGD-70			
		Scale: NTS	Sheet: 6 of 6	Drawing No. 4340	Rev: G